



CONSUMER NOTICE OF TAP WATER RESULTS **FOR COMMUNITY WATER SYSTEMS**

To the Campus Community,

Facilities Planning & Management is pleased to report the results of the lead in tap water monitoring program, conducted on June 2, 2020.

Of the 60 samples collected across the campus, 58 sample locations were tested to be at a Non-Detect level (ND) for lead, and only two samples were above the detection level. Building 28 result is 10 ppb and Building 9 is 50 ppb. Inactivity in those buildings because of the COVID-19 pandemic may have contributed to those results. The campus mitigated the source of lead within those two buildings and pulled repeat samples for retests within each building that resulted in ND level for lead. With the 58 samples resulting at a ND level, the June 2 set of water samples are in compliance with the 90th percentile value for the campus water system that meets or exceeds the standards set by the federal government.

What Does This Mean?

Under the authority of the Safe Drinking Water Act, the U.S. Environmental Protection Agency (EPA) set the action level for lead in drinking water at 15 ppb. This means utilities must ensure that water from the customer's tap does not exceed this level in at least 90 percent of the homes sampled (90th percentile value). The action level is *the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow*. If water from the tap does exceed this limit, then the utility must take certain steps to correct the problem. Because lead may pose serious health risks, the EPA set a Maximum Contaminant Level Goal (MCLG) of zero for lead. The MCLG is *the level of a contaminant in drinking water below which there is no known or expected risk to health*. *MCLGs allow for a margin of safety*.

What Are the Health Effects of Lead?

Lead can cause serious health problems if too much enters the body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of the body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development.

What Are the Sources of Lead?

The primary sources of lead exposure for most children are deteriorating lead-based paint, lead-contaminated dust, and lead-contaminated residential soil. Lead is found in some toys, some playground equipment, some children's metal jewelry, and some traditional pottery. Exposure to lead is a significant health concern, especially for young children and infants whose growing bodies tend to absorb more lead than the average adult. Although your

home's drinking water lead levels were below the action level, if you are concerned about lead exposure, parents should ask their health care providers about testing children for high levels of lead in the blood.

What Can I Do to Reduce Exposure to Lead in Drinking Water?

Although your test results were below EPA's action level, you may still want to take steps to further reduce your exposure.

- **Run your water to flush out lead.** If water hasn't been used for several hours, run water for 15-30 seconds to flush lead from interior plumbing (or insert a different flushing time if your system has representative data indicating a different flushing time would better reduce lead exposure in your community and if CDPH approves the wording) or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
- **Use cold water for cooking and preparing baby formula.**
- **Do not boil water to remove lead.**
- **Look for alternative sources or treatment of water (such as bottled water or water filters).**
- **Re-test your water for lead periodically.**
- **Identify and replace plumbing fixtures containing lead.**

For More Information

Call (909) 869-5189. For additional information on reducing lead exposure around the campus and the health effects of lead, visit the EPA's website at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

Before installing or modifying any equipment that utilizes the campus water in or at a building, submit a service request to Facilities Customer Service for a complimentary assessment by Facilities Management regarding federal, state and local requirements.
Facilities Customer Service, (909) 869-3030

Please send specific questions about the quality of the drinking water supplied on the campus to:

Joseph Phillipy
Chief Operator Water Treatment Plant
Facilities Planning & Management
wateroperations@cpp.edu
(909) 869-5189